



**Cable Assemblies**  
**Part# P-00700-EC & P-00700-IC**

**SPECIFICATIONS**  
**PAGE 1 OF 1**



P-00700-EC, Exterior Cable Assembly (35') standard



P-00700-IC, Interior Cable Assembly (175') standard

**DESCRIPTION**

The interior and exterior cable assemblies provide the connection points for the netting. A continuous cable should be installed along the perimeter of the building using eye bolts and columns if available. The exterior cable assemblies should be connected from pole to pole and should be terminated at each pole.

**INSTRUCTIONS**

1. Measure the distance from center to center of the two brackets the poles are attached to.
2. Add 3" to that length and terminate the non-factory end of the cable to that dimension using a thimble and two wire rope clips provided.
3. Connect both ends of the cable to the outer eyebolts of the poles using the provided shackles.

**WARNING:** Do NOT run a continuous cable between poles. Terminating each cable at each pole at the proper dimensions is crucial to the structural integrity of the system. Failure to properly terminate the cables at each pole at the proper length may cause system failure and injury or death.

**GENERAL SPECIFICATIONS**

Item	Description
Cable	5/16" or 3/8" 7x19 GAC
Shackle	7/16" Bolt Type Safety Shackle, Forged, galvanized
Thimble	Galvanized
Wire Rope Clip	Chair Style Fist Grip Clip, Forged, galvanized
Turnbuckle	1/2" x 12" Jaw & Jaw, Forged, galvanized

**Technical References:**

- (1) Meets OSHA 1926 Subpart M for fall arrest netting when used as part of a complete system.
- (2) Meets ANSI A 10.11 drop test requirements for fall arrest netting when used as part of a complete system.
- (3) Break Strength—N/A